



# DODLEY ENTERPRISE

FIRE SAFETY ENGINEERS & CONSULTANT

Dial: 9435095656  
9706257179  
9854035998

Email: dodlyenter@gmail.com

Your Ref. DE/Cer-20/21  
our Ref.

APPROVED BY:  
DIRECTOR FIRE SERVICE  
STATE FIRE SERVICE ORGANIZATION  
GOVT. OF ASSAM

Date: 26/10/2021

Regd. Off : Gar-Ali, Rajabari, Jorhat-785014

## CERTIFICATE


### INSPECTION CUM TESTING REPORT

Name of the customer	: SPRINGDALE HIGH SCHOOL
Address	: Cinnamara, Jorhat.
Trade	: School Building (Institution)

This is to certify that *Mr. R. Hazarika*... an authorised Service Engineer / Technician has done the Inspection, Testing and Servicing below mentioned Fire - Equipments report which as under-

#### TYPE OF FIRE - EXTINGUISHER

- |     |    |   |    |              |
|-----|----|---|----|--------------|
| (a) | 05 | Kg. Capacity ABC Powder (Stored Pressure) | 11 | Nos (Eleven) |
| (b) | 04 | Kg. Capacity ABC Powder (Stored Pressure) | 02 | Nos (Two)    |
| (a) |    | Kg. Capacity Dry Chemical Powder          |    |              |
| (b) |    | Kg. Capacity Dry Chemical Powder          |    |              |
| (a) |    | Kg. Capacity AFFF type (Mech. Foam)       |    |              |
| (b) |    | Kg. Capacity AFFF type (Mech. Foam)       |    |              |
| (a) |    | Ltrs. Capacity Water CO2 (Cartridge)      |    |              |
| (b) |    | Kg. Capacity Water CO2 (Cartridge)        |    |              |
| (a) |    | Kg. Capacity CO2 (Gas)                    |    |              |
| (b) |    | Kg. Capacity CO2 (Gas)                    |    |              |



Total No. of Extinguisher Thirteen Nos. New Extinguisher: 02

Condition of extinguisher at the time inspection **Active Position**

No. of serviceable extinguisher 13 Next due date of Inspection

Technical any problem of F/E Nil ABC = 05Kgs 26/10/2025 (Old)

ABC = 04Kgs 26/10/2026 (New)

Repairing & Replace any parts

Next due date of Inspection :

All extinguishers are properly installed according to Assam State Fire Service Rule 1989.

Yes

**Remarks:** Inspection & Testing completed. The all extinguishers are properly charged & found satisfactory.

Customers Signature

Date: 26/10/2021

For  **DODLEY ENTERPRISE**